



# Annual Drinking Water Quality Report for Calendar Year 2024

## Village of Arrowsmith

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. This report includes drinking water facts, information on violations (if applicable), and contaminants detected in your drinking water supply during calendar year 2024. Each year, we will provide you a new report. If you need help understanding this report, have general questions, or would like a copy please contact the person listed below.

*Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.*

Contact Name: Corey Edgington  
Telephone Number: 1-217-402-2392  
E-mail (if available) voa.water@gmail.com

Before we begin listing our unique water quality characteristics, here are some important facts you should know to help have a basic understanding of drinking water in general.

### Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our source of water comes from **Ground Water: Well #1 (47604) is south of the Community Center on the East side of Town/Well #2 (01367) is 200 feet North-East of Well #1 and both wells are active**

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

### Other Facts about Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Arrowsmith is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water, you may wish to have your water tested, contact Village of Arrowsmith Water Department at 1-309-727-1116. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

We want our valued customers to be informed about their water quality. If you would like to learn more, please feel welcome to attend any of our regularly scheduled meetings (7pm the first Thursday of every month at the Community Center). The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, please stop by the Community Center or call our water operator at 1-217-402-2392. To view a summary version of the completed Source Water Assessments, including: Importance of Source Water; Susceptibility to Contamination Determination; and documentation/recommendation of Source Water Protection Efforts, you may access the Illinois EPA website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl>.

## Source Water Assessments

Source water protection (SWP) is a proactive approach to protecting our critical sources of public water supply and assuring that the best source of water is being utilized to serve the public. It involves implementation of pollution prevention practices to protect the water quality in a watershed or wellhead protection area serving a public water supply. Along with treatment, it establishes a multi-barrier approach to assuring clean and safe drinking water to the citizens of Illinois. The Illinois EPA has implemented a source water assessment program (SWAP) to assist with wellhead and watershed protection of public drinking water supplies.

To determine Arrowsmith's susceptibility to groundwater contamination, a Well Site Survey, published in 1991 by the Illinois EPA, and Source Water Protection Plan were reviewed. Based on the information contained in these documents, three below ground fuel storage tanks are located proximate to Arrowsmith's community water supply wells. Based upon information obtained, the Illinois EPA has determined that Arrowsmith's wells are not susceptible to IOC, VOC, or SOC contamination. This determination is based on a number of criteria including: monitoring conducted at the well; monitoring conducted at the entry point to the distribution system; and the available hydro geologic data for the wells.

### 2024 Regulated Contaminants Detected

The next several tables summarize contaminants detected in your drinking water supply.

Here are a few definitions and scientific terms which will help you understand the information in the contaminant detection tables.

AL	Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Avg	Regulatory compliance with some MCLs is based on running annual average of monthly samples.
MCL	Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the Maximum Contaminant Level Goal as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL	Maximum Residual Disinfectant Level: The highest level of disinfectant allowed in drinking water.
MRDLG	Maximum Residual Disinfectant Level Goal: The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLGs allow for a margin of safety.
N/A	Not Applicable
ppb	parts per billion or micrograms per liter (ug/L) - or one ounce in 7,350,000 gallons of water.
ppm	parts per million or milligrams per liter (mg/L) - or one ounce in 7,350 gallons of water.

Coliform Bacteria	MCLG	Total Coliform MCL	Highest Number of Positive Samples	Fecal Coliform or <i>E. coli</i> MCL	Total No. of Positive <i>E. coli</i> or Fecal Coliform Samples	Violation	Likely Source of Contamination
	0	MCL: > 1 positive monthly sample (for systems that collect < 40 samples/month).	0	Fecal Coliform or <i>E. coli</i> MCL: A routine sample and a repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	0	NO	Naturally present in the environment

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	Range of Levels Detected	90 <sup>th</sup> Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2024	1.3	1.3	0.03-0.86	0.525	0	ppm	NO	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

To obtain a copy of the system's lead tap sampling data contact Village of Arrowsmith Water Department at 1-309-727-1116

Our Community Water Supply has developed a service line material inventory.

To obtain a copy of the system's service line inventory go to web address: [https://arrowsmithil.gov/documents/532/Arrowsmith\\_Final\\_Material\\_Inventory\\_2024.pdf](https://arrowsmithil.gov/documents/532/Arrowsmith_Final_Material_Inventory_2024.pdf)

Disinfectants & Disinfection Byproducts	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2024	3	1.51-3.91	MRDLG=4	MRDL=4	ppm	NO	Water additive used to control microbes
Haloacetic Acids (HAA5)	7/11/2023	28.5	28.5-28.5	No goal for the total	60	ppb	NO	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	7/11/2023	7.2	7.2-7.2	No goal for the total	80	ppb	NO	By-product of drinking water disinfection

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	5/8/2024	1.4	1.4-1.4	0	10	ppb	NO	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	5/8/2024	0.097	0.097-0.097	2	2	ppm	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride	5/8/2024	0.863	0.863-0.863	4	4.0	ppm	NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
State Regulated Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Iron This contaminant is not currently regulated by the USEPA. However, the state has set an MCL for supplies serving a population of 1,000 or more.	5/8/2024	0.91	0.91-0.91	N/A	1.0	ppm	NO	Erosion from naturally occurring deposits.
Manganese This contaminant is not currently regulated by the USEPA. However, the state has set an MCL for supplies serving a population of 1,000 or more.	5/8/2024	7.6	7.6-7.6	150	150	ppb	No	Erosion from naturally occurring deposits
Sodium Monitoring is required to provide information to consumers and health officials that are concerned about sodium intake due to dietary precautions. If you are on a sodium-restricted diet, you should consult a physician	5/8/2024	92	92-92	N/A	N/A	ppm	NO	Erosion from naturally occurring deposits: Used in water softener regeneration.
Zinc This contaminant is not currently regulated by the USEPA. However, the state has set an MCL for supplies serving a population of 1,000 or more.	5/8/2024	0.029	0.029-0.029	5	5	ppm	NO	Naturally occurring discharge from metal factories.
Note: The state requires monitoring of certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of this data may be more than one year old.								
Note: Due to favorable monitoring history, aquifer characteristics, and inventory of potential sources of contamination, our water supply was issued a vulnerability waiver. Monitoring for Cyanide and SOC <sub>s</sub> is required only every 9 years, VOC <sub>s</sub> only every 6 years, and IOC <sub>s</sub> only every 3 years.								
Note: Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.								

#### Violation Summary Table

We are happy to announce that no monitoring, reporting, treatment technique, maximum residual disinfectant level, or maximum contaminant level violations were recorded during **2024**.